इंटरनेट मानक

Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

"जानने का अधिकार, जीने का अधिकार"
Mazdoor Kisan Shakti Sangathan
"The Right to Information, The Right to Live"

"पुराने को छोड नये के तरफ"
Jawaharlal Nehru
"Step Out From the Old to the New"

IS 11970 (1987, Reaffirmed 2008): Guide for Condensate Polishing (Power Plant). UDC 621.182.448

"ज्ञान से एक नये भारत का निर्माण"
Satyanarayan Gangaram Pitroda
"Invent a New India Using Knowledge"

Act Number 22 of 2005
The Indian Parliament
RIGHT TO INFORMATION

Made Available By
Public.Resource.Org

"ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता है"
Bhartṛhari—Nītiśatakam
"Knowledge is such a treasure which cannot be stolen"

(Reaffirmed 2008)

IS : 11970 - 1987

Indian Standard

GUIDE FOR CONDENSATE POLISHING (POWER PLANT)

UDC 621·182·448

© *Copyright* 1987

BUREAU OF INDIAN STANDARDS
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002

Gr 4 *September* 1987

AMENDMENT NO. 2 DECEEMBER 2008
TO
IS 11970 : 1987 GUIDE FOR CONDENSATE POLISHING (POWER PLANT)

(*Page* 7, *clause* 2.3, *read with Amendment No.* 1) — Substitute '< 2' *for* '< 5' as Specified limit of Sodium, ppb in plant effluent for ammonia cycle operation.

[*Page* 7, *clause* 3.1(a)] — Insert the following at the end:

'Ammonia dosing has to be ensured an auto mode so that *p*H of condensate is maintained in the range of 8.8-9.0 in hydrogen cycle mode of operation.'

(*Page* 10, *clause* 4.3, *line* 6) — Insert the following after the word 'externally':

'Complete resin transfer from service vessel to regeneration vessel and vice versa to be ensured.'

(*Page* 11, *clause* 4.3) — Insert the following at the end:

'Cross contamination of resin to be tested after every 5 regeneration. Screen testing of resin to be tested after every ten regeneration. Chloride content in caustic used for anion regeneration should be compatible with rayon grade and preferably A.R. grade ammonia to be used for boosting *p*H in condensate in hydrogen cycle. Both cation and anion resin quantities are to be made up to the design quantities so as to maintain their interface level in resin separation unit.'

(*Page* 12, *clause* 5, *first para*) — Insert the following at the end:

'Provision of on-line sodium and chloride analyzers to be envisaged. Provision of air mixing in service vessel to be envisaged.'

(*Page* 12, *clause* 5, *second para*) — Insert the following at the end:

'CO_2 content measurement in condensate come in handy to ascertain the ionic load on resin.'

(CHD 13)

Reprography Unit, BIS, New Delhi, India

AMENDMENT NO. 1 NOVEMBER 1994
TO
IS 11970 : 1987 GUIDE FOR CONDENSATE POLISHING (POWER PLANT)

(*Page* 7, *clause* 2.2) — Insert the following after (vi):

'vii) Hollow fibre filter in conjunction with a deep mixed bed demineralizer.'

(*Page* 7, *clause* 2.2) — Add the following new clause 2.3 after 2.2:

'2.3 Chemical Conltrol Specifications regarding typical Condensate Polishing Plant Effluent for Power plant:

Parameter	Hydrogen Cycle Operation	Ammonia Cycle Operation
Cation conductivity after removal of ammonia/amine (µs/cm at 25°C)	< 0.1	< 0.1
Sodium, ppb	< 2	< 5
Chloride, ppb	< 1	< 2
Silica (as SiO2), ppb	< 5	< 5
Soluble iron (as Fe), ppb	< 5	< 5
Soluble copper (as Cu), ppb	< 2	< 2
Crud, ppb	< 10	< 10

(*Page* 8, *clause* 3.3) — Add the following at the end of 3.3:

'With proper separation of cation and anion resins and sufficient (approx. 200 percent) regeneration with pure regenerants (Cl less than 150 ppm in NaOH), the CPP effluent water quality mentioned in 2.3 may be easily achieved.'

(*Page* 9, *clause* 4.1) — Add the following at the end:

'Non steady flow rates can introduce ionic impurity leakages in the effluent due to disturbance of the kinetic equilibrium of the bed.'

(*Page* 12, *clause* 5) — Add the following at the end:

'In addition, it would be advantageous to have an ion chromatographic system available for trace level analysis of important chemical control parameters namely, Chloride, Sodium and Silica'

(CHD 013)

Reprography Unit, BIS, New Delhi, India

Indian Standard

GUIDE FOR CONDENSATE POLISHING (POWER PLANT)

Boiler Water Sectional Committee, CDC 57

Chairman	*Representing*
SHRI P. C. D. G. SAMUEL	Madras Refineries Ltd, Madras
Members	
SHRI J. N. BHOWMIK	West Bengal State Electricity Board, Calcutta
SHRI B. K. SANTRA (*Alternate*)	
SHRI T. M. BALASUBRAMANIAN	Central Electrochemical Research Institute (CSIR), Karaikudi
DR G. VENKATACHARI (*Alternate*)	
SHRI R. N. BANERJEE	Development Consultants Pvt Ltd, Calcutta
SHRI S. K. CHATTERJEE (*Alternate*)	
SHRI D. CHATTERJEE	Delta Enterprises Pvt Ltd, Calcutta
CHEMIST & METALLURGIST II, RDSO, LUCKNOW	Railway Board (Ministry of Railways)
CHEMIST & METALLURGIST (W. R.) (*Alternate*)	
SHRI SOMENATH GHOSE	Jai Guru Engineering Co (India), Calcutta
SHRI ANANDAMOY GHOSE (*Alternate*)	
SHRI VIJAY KUMAR GOEL	Ministry of Industry (Deptt of Industrial Development), New Delhi
SHRI G. T. JADEJA	The Tata Hydro-Electric Power Supply Co Ltd, Bombay
SHRI B. K. GANDHI (*Alternate*)	
SHRI J. JHA	Central Electrical Authority, New Delhi
SHRI KSHIRSAGAR	Maharashtra State Electricity Board, Bombay
DR V. M. KELKAR	Engineers India Ltd, New Delhi
SHRI K. RUDRAPPA (*Alternate*)	
SHRI K. R. KRISHNASWAMY	Central Power Research Institute, Bangalore
SHRI G. UDAYABHASKAR (*Alternate*)	
SHRI S. MAHADEVAN	Chemical Consultants, Madras
DR P. K. MATHUR	Indra Gandhi Centre for Atomic Research (IGCAR), Kalpakkam
SHRI R. NATARAJAN	Bharat Heavy Electricals Ltd, Tiruchirapalli
SHRI T. R. NAGARAJAN (*Alternate* I)	
DR A. PRABHAKAR RAO (*Alternate* II)	
SHRI R. NATARAJAN	Hindustan Dorr-Oliver Ltd, Bombay
SHRI SUBASH VERMA (*Alternate*)	
SHRI ANIL G. PANDIT	Thermax Pvt Ltd, Pune

(*Continued on page* 2)

© *Copyright* 1987
BUREAU OF INDIAN STANDARDS
This publication is protected under the *Indian Copyright Act* (XIV of 1957) and reproduction in whole or in part by any means except with written permission of the publisher shall be deemed to be an infringement of copyright under the said Act.

(*Continued from page* 1)

Members	*Representing*
SHRI C. L. PATEL	The Gujarat Electricity Board, Ukai (Gujarat)
SHRI R. G. MANDAN (*Alternate*)	
SHRI RAM GOPAL	National Thermal Power Corporation Ltd, New Delhi
SHRI R. K. DWIVEDI (*Alternate*)	
SHRI N. RAMACHANDRAN	Ion Exchange (India) Ltd, Bombay
SHRI A. B. TONGAONKAR (*Alternate*)	
DR S. K. ROY	IEL Ltd, Calcutta
SHRI N. B. SAINANI	Indian Farmers Fertilizer Co-operative Ltd, New Delhi
SHRI G. H. JOSHI (*Alternate*)	
SHRI M. V. SASTRY	IAEC Ltd, Bombay
SHRI K. R. SENGUPTA	Hindustan Fertilizer Corpn Ltd, Durgapur
SHRI A. K. BHATTACHARJEE (*Alternate*)	
DR V. K. SETH	Projects & Development India Ltd, Sindri
SHRI D. P. SINGH	Delhi Electric Supply Undertaking, New Delhi
SHRI K. B. CHHABRA (*Alternate*)	
SHRI G. P. SINGH	Steel Authority of India Ltd, New Delhi
SHRI A. P. SINHA (*Alternate*)	
SHRI R. SWAMINATHAN	National Organic Chemical Industries Ltd, Bombay
SHRI M. D. VIJAYARANGAM	Tamil Nadu State Electricity Board, Madras
SHRI V. TULASIRAMAN (*Alternate*)	
SHRI SATISH CHANDER, Director (Chem)	Director General, BIS (*Ex-officio Member*)

Secretary

SHRI S. ARAVAMUDHAN
Joint Director (Chem), BIS

Code of Practice Subcommittee, CDC 57 : 2

Convener	
SHRI P. K. MATHUR	Indira Gandhi Centre for Atomic Research (IGCAR), Kalpakkam

Members	
SHRI B. B. AJMANI	Railway Board (Ministry of Railways)
SHRI C. D. DIXIT (*Alternate*)	
SHRI D. K. GANDHI	The Tata Hydro-Electric Power Supply Co Ltd, Bombay
SHRI K. M. KURDEKAR (*Alternate*)	
SHRI VIJAY KUMAR GOEL	Ministry of Industry (Deptt of Industrial Development), New Delhi
SHRI S. MAHADEVAN	Chemical Consultants, Madras
SHRI C. S. RAGHAVAN (*Alternate*)	
SHRI R. NATARAJAN	Bharat Heavy Electricals Ltd, Hyderabad
SHRI T. BALAKRISHNAN (*Alternate*)	

(*Continued on page* 14)

Indian Standard

GUIDE FOR CONDENSATE POLISHING (POWER PLANT)

0. FOREWORD

0.1 This Indian Standard was adopted by the Indian Standards Institution on 27 February 1987, after the draft finalized by the Boiler Water Sectional Committee had been approved by the Chemical Division Council.

0.2 In the power industry, both nuclear and thermal, concentration of impurities, coming in from condenser tube leaks, in certain localized areas of steam generators/boilers could be of several orders of magnitude higher than that indicated by routine bulk boiler water analysis. As boiler operating pressures and steaming rates have continually increased, this localized impurity concentration effect has become increasingly predominant. Surveys conducted on the operating experiences of high pressure boilers/steam generators all over the world have indicated that in addition to engineering and metallurgical choices like design, appropriate selection of constructional materials and fabrication techniques as well as good operational practices, an efficient boiler water chemistry control played a very major role in ensuring boiler tube integrity. It is now well recognized that an efficient boiler water and steam chemistry control should necessarily start at boiler feed water stage itself. With the present day knowledge and understanding of the complex nature of local concentration mechanisms occurring in power station boilers, particularly in nuclear steam generators, and the attendant specific corrosion problems, namely, general wastage and gouging, pitting, denting corrosion, crevice corrosion, transgranular and intergranular corrosion, etc, use of high purity feed water (Na < 2 ppb; chloride < 2 ppb; sulphate < 2 ppb; specification conductivity < 0·1 μs/cm; silica as SiO_2 < 10 ppb), with all volatile treatment (AVT) for alkalinity and dissolved oxygen control, is currently recommended for maintaining proper boiler water and steam chemistry regime. Recently some of the turbine manufacturers are also specifying steam quality (SiO_2 < 10 ppb; Na < 3 ppb; chloride < 5 ppb; cationic conductivity < 0·2 μs/cm) to avoid stress corrosion cracking in certain high strength steels used in modern compact high rating turbines. To meet the above mentioned feed water and steam quality specifications it becomes essential to opt for full flow condensate polishing. Thus incorporation of a full flow condensate polishing plant (CPP) is today considered advisable

for plants using sea water for condenser cooling and even for those where condenser cooling water has salinity more than 2 000 ppm. In those cases where the cooling water is of less than 2 000 ppm salinity, it is now considered worthwhile to review the requirement of a CPP. Although the concept of full flow condensate polishing emerged with boiling water nuclear power reactors (BWRs), it is now being increasingly employed for pressurized water and pressurized heavy water nuclear power reactors (PWRs and PHWRs), fast breeder reactors and large modern thermal power plants using once-through or high pressure boilers. For once-through boilers in particular, full flow condensate polishing becomes inevitable as there exists no drum for accumulation and consequent blow down of harmful impurities.

1. SCOPE

1.1 This guide prescribes objectives, performance criteria and possible methods of condensate polishing for boilers for power plants.

2. OBJECTIVES

2.1 Condensate polishing plants have two basic functions:

a) to cope with the ionic and non-ionic or dissolved and suspended impurities entering into the steam condensate due to ingresses of impure cooling water through condenser tube leakages; and

b) to remove impurities generated by corrosion or erosion of constructional materials. These corrosion products could be both soluble and insoluble.

The performance criteria of such plants are that they should provide the required quality and quantity of water and be able to cope with changing operational conditions, for example from commissioning to base load, to allow continuous operation with minor condenser leak, and to provide time for safe shut down in an emergency, such as a large ingress of cooling water. With drum type boilers, the inclusion of CPP reduces the frequency of chemical cleaning of the boiler and cycle heat rates can be improved as a result of reduced blow down.

2.2 Types of Condensate Polishing Systems

The soluble contaminants can be removed by demineralization and insolubles by filteration. Conventional sand filters have been found to be inadequate for removal of corrosion products in the particle sizes encountered in the steam condensate and for the high flow rates they also occupy too much space. On the other hand pressure pre-coat candle type of filters (using inert cellulose fibrous material, eg, alpha cellulose material for pre-coat) have very good removal efficiencies for 5 micron

size particles and in addition, occupy much lesser space. However, the system has been almost abondened due to uneven precoating, resulting in unsatisfactory removal of crud, sloughage from the pre-coat filter causing fouling of the anion resin and heavy capital cost.

The dual purpose of filtration and demineralization can be achieved by the 'powdex process' by using finely ground cation and anion resins (about 25 micron size) as the pre-coat material along with alpha cellulose. The pre-coat normally consists of 0·5 kg/m^2 each of cation and anion resins and 0·2 kg/m^2 of the fibrous inert material (like alpha cellulose) and has a retention capacity of about 65 g iron/m^2. One clear advantage of the finely ground resin is its capacity to withstand higher temperatures and its better efficiency for the removal of colloidal, hydrated iron oxide. This makes it possible to install finely ground resin filter just upstream of the deaerator, thus helping in the removal of crud picked up from the tube side of the low pressure heaters. However, these filters/demineralizers are non regenerable type and the resins have to be discarded after exhaustion. Hence the operating costs of these units are about 10 times higher than that of deep bed demineralizers. In addition, these are not able to fully cope with the ionic impurities coming in from condenser tube leakages, and this is particularly true for sea water cooled plants.

Experience has shown that deep (about 1 metre bed depth) mixed bed demineralizer units provide optimum cost benefit ratio while realizing adequate protection against ionic impurity ingresses into the steam condensate from condenser tube leaks. However, with these units, crud removal efficiency is relatively low and their use requires proper design and establishment of correct operating practices for smooth functioning and minimizing/avoiding resin fouling by crud. In addition, reliability of process instrumentation (conductivity meters, flow integrators, differential pressure indicators, etc) is an essential requirement.

A comparative account of the advantages/disadvantages of powdex system *vis-a-vis* deep bed system may be given as follows:

Sl No.	*Powdex System*	*Deep Bed System*
1.	Removes crud, and colloidal particles efficiently because of large surface area.	Not so efficient in removal of crud.
2.	Unit is ready in a short time (back washing and pre-coating) and not very elaborate equipment is required for this.	Takes longer time for regeneration and a complete regeneration system is required. The system has to be located outside of turbine building to avoid damage to other equipment in turbine building by regenerant chemicals, fumes, etc.

3.	Waste effluents are harmless and small in quantity.	Unspent and exchanged chemicals go as waste effluents during regeneration and their quantity is also large.
4.	Since always fresh resin coat is used, so resin is in highly regenerated state every time resin is replaced.	Regeneration efficiency is limited due to incomplete separation of cation and anion components.
5.	Influent water temperature can be high (up to 80°C).	Temperature restriction is 60°C.
6.	Resins can not be regenerated and are to be discarded.	Resins are regenerated and indigenously available.
7.	Resin shelf life is very short (about 6 months) and filter cartridge life also is limited (about 1 year).	Shelf life is around 5 years if properly maintained.
8.	Pre-coat requires vacuum holding pump, which if gets interrupted due to power supply failure, gets disturbed.	No such problem here.
9.	Cation/anion resins ratio has to be varied with respect to types and concentration of impurities and plant conditions (ratio to be different at start-up, normal service time, during condenser tube leakage, etc).	No such problem here.
10.	Silica removal efficiency is low.	Silica removal efficiency is high.
11.	Operating capacity is limited.	Operating capacity is large.

In addition to the above two methods, namely, powdex process and deep bed demineralization, combinations of these two and other methods are also employed. These are:

i) Pre-coat cellulose filter + strong acid cation unit + mixed bed unit.

ii) Strong acid cation unit + mixed bed unit.

iii) Pressure pre-coat filter using powdex + mixed bed unit.

iv) Magnetic and/or deep graphite bed filters/mixed bed units.

v) Cation layered mixed bed.

vi) Activated carbon filter + strong acid cation unit + mixed bed unit.

3. CONDITIONING METHODS

3.1 Chemical Conditioning and Condensate Polishing Plant Operation/Performance

The feed water chemical conditioning regime has a considerable influence on CPP Operation/performance. In utilities using AVT, hydrazine or morpholine exchange by cation resins can hamper polishing function. As very scanty information is available in the literature regarding the effect of hydrazonium ($N_2H_5^+$) and morpholinium ion on cation exchange resin performance, subsequent discussion is restricted to the effect of ammonium ion alone.

Originally low ammonia levels [0·2 to 0·5 ppm (as NH_3); *p*H 8·8 to 9·2] were specified in the condensate, but to take account of world wide experience of erosion/corrosion, various utilities have considered the possibility of operating at higher *p*H (9·4 — 9 6) provided the system is free of copper bearing alloys in the feed train.

The adoption of high *p*H conditioning would impose an additional load of ammonium ion on a CPP operating in the hydrogen/hydroxide form. There would be approximately a three fold increase in the concentration of ammonium ions to be removed by raising the *p*H from 9·0 to 9·4 or a seven fold increase if the *p*H were increased to 9·6. The following are four main approaches for treating condensate:

a) Operation could continue with the cation resin in the hydrogen form thus greatly increasing the number of regenerations.

b) The system could operate with the cation resin in the ammonium form, so that ammonium ion would no longer be removed and the service period would then be dictated by pressure drop, conductivity, silica slip, etc.

c) The initial operation has the cation resin in hydrogen form and after ammonia break-through, the cycle is continued in ammonium form.

d) To operate with the CPP on stand-by until condenser leaks occur.

3.2 Hydrogen Cycle Operation

Two factors control the ability of a CPP (hydrogen form cation operation) to operate satisfactorily with increased ammonia loadings.

These are: (a) the running period that is possible before exhaustion of the bed, and (b) the time required to regenerate the bed. As on a regular basis regeneration of one bed takes substantially long time, any changes that could be made to offset the decreased service run lengths due to higher ammonia content in the condensate would be beneficial. Increasing the regeneration level of the acid used for the cation resin has been considered as one possibility.

For the CPP with cation resin units preceding the mixed bed, it has been found that by applying an increased regeneration level (200 kg/ m^3) sulphuric acid, an increased service run length could be achieved while treating condensate containing 2·2 ppm ammonia (*p*H 9·6), provided the inflow water characteristics are the same. Hydrochloric acid is also used widely for regeneration. On the other hand for the CPP with finely ground resin units and mixed bed, there is a much less inventory of cation resin and this restricts the ability of the plant for treating condensate of higher ammonia levels. Applying the concept of increasing the capacity of cation resins by employing higher regeneration levels, it should be possible to treat condensate containing 1·1 ppm ammonia (*p*H 9·4). Thus under hydrogen cycle operation, increasing the level of cation resin regenerant chemical could provide a viable option for operating CPP at higher *p*H levels in condensate. However, it is essential to emphasis for the design provision for adequate cation removal capabilities to cope with flexibility of operation with respect to the conditioning of feed water with ammonia.

3.3 Ammonia Cycle Operation

Another chemical option for operating CPP treating condensate at *p*H 9·6 would be to use the cation resin in ammonium form. In the absence of condenser leaks very long service lengths would be possible and the regeneration will then be dictated by differential pressure across the bed due to accumulation of filtered crud. However, one has to consider two important points, namely, (a) production of water of required quality, and (b) ability of such a system to cope with cooling sea water ingress from condenser leaks. It should be noted that there is very little experience any where in the world on the use of ammonium form resins with sea water cooled power stations. However, it is known that use of cation resins in ammoniated form to reduce ammonia consumption results in higher sodium leakage during condenser tube leakage periods. Also there is a general agreement in the literature that in this mode of operation the resins will have to be in a very high state of regeneration. It has been estimated that less than 0·08 percent of cation sites can be in the sodium form and less than 1·9 percent of anion sites in the chloride form in order to achieve a condensate containing less than 1 ppb sodium and 2 ppb chloride at *p*H 9·6. Comparative figures for hydrogen cycle operation are quite large for cation and anion resins.

These figures clearly indicate that extremely good separation of resins prior to regeneration and very eflective regeneration techniques are essential for operation in the ammonium form, if stringent conditions for high purity feed water are to be maintained.

3.4 Operation with CPP By-passed

A third approach for operating under a high *p*H regime would be to by-pass the CPP until condenser leakage occurs. In the absence of the CPP unit there would be no extra dosing of chemicals and the bed would be maintained in a highly regenerated state. However, in this mode of operation, the disadvantage is the difficulty in deciding when to reinstate CPP , particularly if cooling water leakage is at a very low level. There is also a need to have a satisfactory working mechanism to ensure that the plant goes into service immediately when it is required.

4. DESIGN CONSIDERATIONS

4.1 Flow Rates

Condensate polishing involves processing of quite high flow rates. To optimise on resin and equipment cost and to reduce space requirement it is necessary to have high flow rate demineralizers. Mechanical design, resin attrition loss, acceptable impurities, leakage past demineralizer and pressure drop considerations have led to the acceptable process flow rates of 120 metres/hour velocity and resin bed depth of about 1 metre.

In CPP, where mixed bed is utilized for filtration as well as ion exchanger, provision has to be kept by incorporating a recirculation pump to see that flow rates do not drop below 60 m/h to provide an optimum filtration efficiency during start up conditions. Flow rates below this value will result in poor filtration efficiency.

4.2 Resin Type Selection and Ratio

High flow rate deep bed demineralization imparts certain limitations on physical characteristics of the ion exchange resin use. Particle size and grading are important from the point of view of reducing pressure drops. In addition, higher attrition strength is required. Particle size and grading are normally specified and require careful selection. The beads should be perfectly spherical without any surface cracks (when viewed under magnifying glass) and there should be no organic colour throw after initial regeneration. 'Slide-test' or 'Chattillion test' are normally followed for checking the bead strength. By field experience it has been observed that on an average if the resin beads require 350 g or more to deform or break, attrition strength of the resin can be considered satisfactory (no more than 5 percent of the tested water swollen beads should require below 200 g for deforming or breaking).

Normally resins used for condensate polishing are strongly acidic cation and strongly basic anion polystyrene — divinyl benzene type with 8-10 percent cross linking. The choice of the resin to be used is between macroporous and gel type. The former have frequently been chosen on the basis of their greater physical strength and for their capacity to take care of any organic fouling, if expected in the power plant condensate. However, conventional gel type of resins have advantages of (a) their higher operating capacity (macroporous resins generally have 10 to 20 percent less operating capacity for cation resins and about 30 percent less operating capacity for anion resins), (b) better kinetic performance, and (c) being less affected by cross contamination of regenerants. Investigations are still in progress all over the world to determine the 'best' resins for particular conditions in condensate polishing plants.

Resin ratio is to be decided on the basis of whether the plant is to be primarily used for crud removal or for protection under condenser leakages. Depending upon the specific use situation and the amounts of chemicals (hydrazine and ammonia or cyclohexylamine or morpholine) being added to the feed water, the cation to anion resin ratio could vary from 2 : 1 by volume (capacity ratio 3 : 1) to 2 : 3 by volume (capacity ratio 1 : 1).

4.3 Regeneration Systems

The aim of the regeneration system is to both remove particulate matter and chemically regenerate the resin beds. The process can be time consuming especially if significant amounts of particulate crud have to be removed. In earlier years, regeneration of a mixed bed polisher was carried out *in situ*. However, now a days, it has become a rule rather than an exception to carry out the regeneration externally. External regeneration, not only reduces the total outage time required for regeneration, but has the greatest advantage of completely eliminating the danger of regenerants entering the system and also helps in achieving more thorough clean up of the resins. The cleaning of the resins can be carried out by one of the following methods:

a) *Back Washing* — Prior to and after acid or caustic injection. Back washing flow rates are such that bed expansion is 100 percent and whole beads are not lost. During this process fine/broken beads are also eliminated.

b) *Air Scrubbing/Rinsing Operation* — Air scrubbing of resins is done in the tank with water up to resin top surface (for one minute), vessel pressurized with air (0·4 to 0 5 kg/cm^2) and down flow rinse given by releasing pressure through rinse outlet for two minutes. This cyclic operation is repeated a number of times.

c) *Ultrasonic Cleaning* — Ultrasonic cleaning devices have now been developed to clean the resins by ultrasonic transducers mounted

outside a cleaning tank. The resin slurry is introduced from top of the tank with reverse water flow from bottom to top to carry away loosened crud and resin fines.

When a CPP is operating with high impurity burden, it is the regeneration time that ultimately governs the availability of the CPP. Therefore, a complete regeneration system plus storage for a regenerated spare charge of resin should be considered for each individual CPP. The leakage of trace impurities from CPP is a function of the regeneration procedure, particularly the degree of contamination of mixed bed resins by the wrong regenerant and the methods to minimize such contamination are quite important. The pertinent factors are:

i) Sodium removal from all the cation resin has to be of a very high degree. This calls for complete transfer of all resin charges and better resin separation.

ii) Anion resin contamination of cation resin must be avoided in order that the sulphate leakage immediately after regeneration is prevented.

iii) The chosen regeneration levels must achieve the correct degree of conversion of both cation and anion resins.

iv) The rinse procedures must be satisfactory.

In the past the usual design philosophy has been to accept some anion resin in cation in order to minimize cation resin contamination of anion. The commonly used tehnique of sluicing anion resin after separation into a separate vessel, usually causes sufficient turbulence to lift some anion resin into the rise space; this resin then settles down on top of the cation resin at the end of the anion resin transfer period.

The desire to avoid anion contamination of cation resin has led to the concept of hydraulic separation of the two resins followed by hydraulic removal of the cation resin from beneath the anion. This development was helped considerably by the introduction of an inert bead form resin of intermediate particle size and density between the cation and anion resins. This introduction required special grading of the ion exchange resins, in which the fine beads of cation resin and the large beads of anion resin have been removed in order that three distinct sharply divided layers are obtained on backwash. Generally now, use of inert resin is not recommended especially during initial stages (plant commissioning stage) because inert resin gets affected by the coating given on turbine blades, etc, for preservation during its erection, etc. The coating makes the inert resin lighter than anion resin so that during mixed bed back-wash for separation, inert resin comes on top of the anion resin.

5. OPERATING GUIDELINES AND ANALYTICAL INSTRUMENTATION

An effluent conductivity of 0·07 μs/cm means a total maximum leakage of about 7 ppb of soluble sodium chloride, sulphate and metals, etc. Ability of condensate polishing units to maintain this level of effluent quality under normal and abnormal (during condenser leakage) conditions for sufficient length of time depends on (i) cleanliness of resins, (ii) extent of condenser tube leak, and (iii) residual ion exchange capacity of the resins at the time of leak. It is thus necessary to have established guidelines to help the operator at the right judgement under various conditions of condensate polisher bed and condenser tube leaks. Cleanliness of the bed is ascertained by differential pressure (dp) measurements across the bed. For a specific design and resins used the 'dp' depends on the flow rate through the demineralizers and resin cleanliness. Hence, the relationship between 'dp' and flow rates has to be established. When the 'dp' approaches dirty limits, the bed is to be transferred to the regeneration facility, cleaned by air scrubbing/rinsing operation and brought back for rinse.

The high quality of feed and steam generator water cannot be achieved without adequate on line instrumentation and back up laboratory analysis techniques and schedules. On-line analysers for sodium (using glass membrane electrodes and buffering techniques) with detection limit of 1 ppb have been developed and methods up to 0·1 ppb are likely to be developed. Similar work is going on for development of chloride ion selective electrodes. On-line silica analysers with detection limit up to 10 ppb are already available. It is felt that with proper sampling and calibration procedures, reliance can be put on the on-line conductivity meters with on-line sodium analysers and pH meters serving a secondary function. These on-line instruments should be used to indicate trends and do alarm functions while exact control should be by proper plant design backed-up by precise laboratory measurement methods and good analysis schedules.

6. ADVANTAGES AND LIMITATIONS OF CONDENSATE POLISHING SYSTEM

6.1 Advantages

a) The water chemistry of the unit can be maintained within specified limits and the system can be kept free of corrosion products, deposits, dissolved and suspended impurities. In nuclear power plants (BWRs) this will go a long way in keeping the inventory of activation products low.

b) Since make-up joins return condensate before CPS, some contamination of DM water in storage tanks or deterioration in DM water quality due to leaks from DM plants can be taken care of by CPS without having to reject the DM water.

c) Provision of CPS will reduce the need of blow down of boiler, thus resulting in saving of DM water.

d) Since by providing CPS, unit can be taken on full load quickly from cold start up, so there will be time saving as well as DM water saving as condensate dumping will be considerably reduced.

e) Points (iii) and (iv) will also obviously, result in fuel saving.

f) In case of condenser leaks not being major, unit can be still kept on load without adversely affecting the water chemistry of the unit and without having to dump condensate or boiler water.

g) Attempration spray water quality will be uniformaly maintained.

6.2 Limitations

Suitable precautions should be taken to avoid the following:

a) In case of deep bed condensate polishing system, immediately after regeneration the bed may leak-out some residual regenerant chemicals thus contaminating feed water quality.

b) Any disintegation of resin in CPS will directly cause contamination of feed water by disintegrated resin.

c) Since CPS is installed in the main steam water circuit, it may result in operational disturbances such as excess pressure drop across CPS

d) Pressure and temperature of influent to CPS may not be always compatible with the design conditions. This may impair the resin characteristics.

(*Continued from page* 2)

Members	*Representing*
SHRI SAMIR KUMAR PAL	Development Consultants Pvt Ltd, Calcutta
SHRI TUSHAR KANTI ROY (*Alternate*)	
SHRI S. M. C. PILLAI	National Thermal Power Cordoration Ltd, New Delhi
SHRI S. DASGUPTA (*Alternate*)	
SHRI N. RAMACHANDRAN	Ion Exchange (India) Ltd, Bombay
SHRI A. B. TONGAONKAR (*Alternate*)	
SHRI M. A. RAMANAN	Central Electricity Authority, New Delhi
SHRI J. JHA (*Alternate*)	
DR SANDIP ROY	IEL Limited, Calcutta
SHRI R. BHARGAVA (*Alternate*)	
DR V. K. SETH	Project Development India Ltd, Sindri
SHRI H. K. MITTAL (*Alternate*)	
SHRI Y. P. SINGH	Delhi Electric Supply Undertaking, New Delhi
SHRI S. N. JUNEJA (*Alternate*)	

BUREAU OF INDIAN STANDARDS

Headquarters:

Manak Bhavan, 9 Bahadur Shah Zafar Marg, NEW DELHI 110002

Telephones : 331 0131 331 1375 Telegrams : Manaksanstha (*Common to all Offices*)

Regional Offices:	*Telephone*
*Western : Manakalaya, E9 MIDC, Marol Andheri (East) BOMBAY 400093	6 32 92 95
†Eastern : 1/14 C. I. T. Scheme VII M, V. I. P. Road, Maniktola, CALCUTTA 700054	35 24 99
Northern : SCO 445-446, Sector 35-C CHANDIGARH 160036	2 18 43 3 16 41
Southern : C. I. T. Campus, MADRAS 600113	41 24 42 41 25 19 41 29 16
Branch Offices:	
'Pushpak', Nurmohamed Shaikh Marg, Khanpur AHMADABAD 380001	2 63 48 2 63 49
'F' Block, Unity Bldg, Narasimharaja Square, BANGALORE 560002	22 48 05
Gangotri Complex, 5th Floor, Bhadbhada Road, T. T. Nagar, BHOPAL 462003	6 67 16
Plot No. 82/83, Lewis Road, BHUBANESHWAR 751002	5 36 27
53/5 Ward No. 29, R. G. Barua Road, 5th Byelane, GUWAHATI 781003	—
5-8-56C L.N. Gupta Marg, HYDERABAD 500001	23 10 83
R14 Yudhister Marg, C Scheme, JAIPUR 302005	6 34 71 6 98 32
117/418 B Sarvodaya Nagar, KANPUR 208005	21 68 76 21 82 92
Patliputra Industrial Estate, PATNA 800013	6 23 05
Hantex Bldg (2nd Floor), Rly Station Road, TRIVANDRUM 695001	52 27
Inspection Office (With Sale Point):	
Institution of Engineers (India) Building, 1332 Shivaji Nagar, PUNE 411005	5 24 35

*Sales Office in Bombay is at Novelty Chambers, Grant Road, BOMBAY 400007 — 89 65 28

†Sales Office in Calcutta is at 5 Chowringhee Approach, P.O. Princep Street, CALCUTTA 700072 — 27 68 00

Printed at Printograph, New Delhi, India